

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

1898

Dated: 08/07/2025

It is certified that an inspection team headed by Sh. Daeshon Karmar SDE & Sh. Gouind Singh (JE)
From District, Division-2 Batala PHED inspected the **BABA MEHMA SAHIB**
PUBLIC SENIOR SECONDARY SCHOOL, MOHLOWALI on 27.06.2025 and on the
basis of Water Test Report (Attached) bearing no RWT/LSR/2526/000883
dated 30/06/2025 of Regional Water Testing Lab, Amritsar.
certified that the **BABA MEHMA SAHIB PUBLIC SENIOR SECONDARY SCHOOL**
has safe drinking water facilities for the students and members of staff of the institution
.School is also maintains the hygienic sanitation condition in the school building & the
campus as per norms prescribed by the Punjab Govt.
This certificate is valid till 31-03-2026

Executive Engineer

Signature with Seal: W/S. and Sanitation Division-2

BATALA

Name: S.S. Shalimar

Designation: Executive Engineer

Name & address of the office / Department:...

Executive Engineer, W/S & Sanitation
Division No 2 Batala

To

BABA MEHMA SAHIB PUBLIC

SENIOR SECONDARY SCHOOL, MOHLOWALI

Joginder Singh

Principal

Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)

Ranjit Kaur

Manager

Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

SDE Water Supply and Sanitation Sub Division No.4 Batala
SDE Water Supply and Sanitation Sub Division No.4 Batala


No.: RWTLASR/2526/00383 Dated : 30/06/2025

Subject : Testing Reports of Water Samples.


Reference: Your Letter/SRF No. 1126 Dated: 27/06/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 27/06/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar


D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Amritsar



Principal
Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)



Manager
Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com



TC-13602

TEST REPORT			
Name & Address of Customer : SDE Water Supply and Sanitation Sub Division No.4 Batala SDE Water Supply and Sanitation Sub Division No.4 Batala		Customer Reference No.	No : 1126 Dated : 27/06/2025
		Sample Submitted by	Mr.Pargat Singh
		Date of Sample Receipt	27/06/2025
		Analysis Starting Date	27/06/2025
		Analysis completion Date	28/06/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC136022500000535F	Sample Type :	Water
Test Report No.:	RWTLASR/2526/00383	Date of Issue :	30/06/2025
Registration no.:	RWTLASR/REG2526/02972	Condition of Sample :	Sealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	500 ml / HDPE Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Baba Mehma Sahib Public Sen.Sec.School,Village Mohlowali,Dera Baba Nanak(S/pump 350 ft),Sample Collected By Gobind Singh JE (9876641931) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Gurdaspur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.27@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	156	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	1.00@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	120	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	100	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	20.84	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	11.66	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	15.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Joginder Singh
Principal
Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)

Ranscet Kaur
Manager
Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)

Pardeep
Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar

End of the Test Report

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

SDE Water Supply and Sanitation Sub Division No.4 Batala
SDE Water Supply and Sanitation Sub Division No.4 Batala

No.: RWTLASR/2526/00383 Dated : 30/06/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 1126 Dated: 27/06/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 27/06/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report

Joginder Singh
Principal
Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)

Randeep
Authorized Signatory
For, Regional Water Testing Lab
Amritsar

Ranjeet Kaur
Manager
Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

TEST REPORT						
Name & Address of Customer : SDE Water Supply and Sanitation Sub Division No.4 Batala SDE Water Supply and Sanitation Sub Division No.4 Batala			Customer Reference No.		No : 1126 Dated : 27/06/2025	
			Sample Submitted by		Mr.Pargat Singh	
			Date of Sample Receipt		27/06/2025	
			Analysis Starting Date		30/06/2025	
			Analysis completion Date		30/06/2025	
Discipline : Chemical Testing			Group: Water			
ULR No.:				Sample Type :		Water
Test Report No.:		RWTLASR/2526/00383		Date of Issue :		30/06/2025
Registration no.:		RWTLASR/REG2526/02973		Condition of Sample :		Sealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		500 ml / HDPE Bottle
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		Baba Mehma Sahib Public Sen.Sec.School,Village Mohlowali,Dera Baba Nanak(S/pump 350 ft),Sample Collected By Gobind Singh JE (9876641931) / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Gurdaspur
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Aluminium(Al)	BDL(0.010)	0.03	0.2	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
2	Lead	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
3	Selenium	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
4	Chromium(Cr)	BDL(0.005)	0.05	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
5	Mercury	BDL(0.0005)	0.001	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
6	Arsenic(As)	0.010	0.01	No relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
7	Cadmium(Cd)	BDL(0.001)	0.003	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
8	Nickel	BDL(0.005)	0.02	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
9	Iron(Fe)	BDL(0.005)	1	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
10	Copper(Cu)	0.014	0.05	1.5	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
11	Uranium	BDL(5)	30	No Relaxation	µg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
12	Manganese(Mn)	BDL(0.005)	0.1	0.3	mg/l	APHA (24th Ed. 2023) Method :3125 B By ICPMS
13	Zinc(Zn)	BDL(0.01)	5	15	mg/l	APHA (24th Ed. 2023) Method: 3125 B By ICPMS

Continue on next page...

Reviewed and Approved By

Jaginder Singh
Principal
Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)

Ramseet Kumar
Manager
Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)

Pardeep
Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar

REGIONAL WATER TESTING LAB, AMRITSAR

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.


rwtlasr1@gmail.com

14	Barium	0.078	0.7	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
----	--------	-------	-----	---------------	------	---

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit: $50 \pm 20\%$

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Amritsar

----- End of the Test Report -----

Joginder Singh
Principal

Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)

Ranjit Kaur
Manager

Baba Mehma Sahib Public
Senior Secondary School
Mohlowali (Gsp.)